

# Kliješta mehaničarska, okrugla

476/1VDEBI



## Profili



## Standardi


DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018



## Atributi proizvoda

- materijal: poseban alatni čelik
- kovana, potpuno poboljšana i ojačana
- čeljusti polirane
- završna obrada: kromiranje po standardu ISO 1456:2009
- robusne ručke izolirane dvokomponentnim navlakama
- izrađeno po standardu ISO5745 i EN IEC 60900

## Prednosti:


- dugi vrhovi omogućavaju pristup žicama u teže dostupnom prostoru
- mala mogućnost oštećenja žice



	L	B	A	C	D	
610431	140	15	9	39	2	116
610432	160	16	10	49	2.5	126

\* Slike proizvoda su simbolične. Sve dimenzije su u mm, masa je u g.

## Upotreba (pictures)



## Frequently asked questions

### **Are certified insulated tools made through a different procedure than non-certified insulated tools?**

The tools are made according to the same procedure.

### **Are insulated (VDE) tools considered as personal protective equipment (PPE)?**

According to EU regulations, VDE tools are not considered as PPE.

### **Is it possible to work with insulated pliers under electrical voltage?**

Yes, but only by professionals who follow safety requirements and use additional personal protective equipment.

### **Are the VDE tools only being sampled in series production?**

The high voltage test (at 10kV) is performed fully on each tool. Other tests are performed in accordance with the EN60900 standard.