

Szigetelt kerek csőrű fogó

476/1VDEBI



Profilok



Szabványok


DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018



Termékjellemzők

- anyaga: Premium Plus szénacél
- kovácsolt, teljes anyagában nemesített
- fej polírozott
- felületkezelés: krómozott, ISO 1456:2009 szabvány szerint
- megerősített, kétkomponensű markolat
- ISO 5745 és EN IEC 60900 szabványok szerint

Előnyök:


- a hosszú csőr nehezen hozzáférhető vezetékeket is képes elérni
- vezeték sérülésének esélye minimális



	L	B	A	C	D	
610431	140	15	9	39	2	116
610432	160	16	10	49	2.5	126

* A termékképek illusztrációk. Minden feltüntetett méret milliméterben, a tömegek grammban. Az összes feltüntetett méret eltérhet a toleranciának megfelelően.

Használat (pictures)



Frequently asked questions

Are certified insulated tools made through a different procedure than non-certified insulated tools?

The tools are made according to the same procedure.

Are insulated (VDE) tools considered as personal protective equipment (PPE)?

According to EU regulations, VDE tools are not considered as PPE.

Is it possible to work with insulated pliers under electrical voltage?

Yes, but only by professionals who follow safety requirements and use additional personal protective equipment.

Are the VDE tools only being sampled in series production?

The high voltage test (at 10kV) is performed fully on each tool. Other tests are performed in accordance with the EN60900 standard.